

SUMMARY 1234 Main St.New City NY 10956 **Buyer Name** 10/23/2017 9:00AM

Dennis Ciallela InterNACHI Certified Home Inspector **DenCia Inspection Services** 845-893-3171 denciainspections@gmail.com



2.1.1 Coverings SHINGLES MISSING

Observed areas that appeared to be missing sufficient coverings. Recommend qualified roofing contractor evaluate & repair.

Recommendation Contact a gualified roofing professional.



2.2.1 Roof Drainage Systems DEBRIS

Debris has accumulated in the gutters. Recommend cleaning to facilitate water flow.

Here is a DIY resource for cleaning your gutters.

Recommendation Contact a qualified roofing professional.



2.2.2 Roof Drainage Systems DOWNSPOUTS DRAIN NEAR HOUSE

One or more downspouts drain too close to the home's foundation. This can result in excessive moisture in the soil at the foundation, which can lead to foundation/structural movement. Recommend a gualified contractor adjust downspout extensions to drain at least 6 feet from the foundation.

Here is a helpful DIY link and video on draining water flow away from your house.

Recommendation

Contact a qualified roofing professional.



2.3.1 Flashings

Flashings observed to be loose or separated, which can lead to water intrusion and/or mold. Recommend a qualified roofing contractor repair.

Recommendation Contact a qualified roofing professional.

2.4.1 Skylights, Chimneys & Other Roof Penetrations SKYLIGHT CRACKED Safety Hazard and/or Requires Immediate Attention

Skylight was cracked in one or more places. Recommend a qualified roofing contractor repair.

Recommendation Contact a qualified roofing professional.





Broken skylight presents risk of water entry and glass shards entering house.

3.4.1 Decks, Balconies, Porches & Steps DECK - WATER SEALANT REQUIRED

Deck is showing signs of weathering and/or water damage. Recommend water sealant/weatherproofing be applied.

Here is a helpful article on staining & sealing your deck.

Recommendation Recommended DIY Project



3.6.1 Vegetation, Grading, Drainage & Retaining Walls

STANDING WATER

Standing water observed, which could indicate poor drainage and/or grading. Recommend monitor and/or have landscaper correct.

Here is a resource on dealing with standing water in your yard.

Recommendation Contact a qualified landscaper or gardener.



Water pooling in yard; recommend drainage

4.4.1 Wall Structure EVIDENCE OF STRUCTURAL DAMAGE ▲ Safety Hazard and/or Requires Immediate Attention

Evidence of structural damage was found in the wall structure. Recommend a structural engineer evaluate and advise on how to repair.

Recommendation Contact a qualified structural engineer.



5.1.1 Equipment FILTER DIRTY

The furnace filter is dirty and needs to be replaced every 6 months.

Recommendation Contact a qualified HVAC professional.



5.1.2 Equipment MANIFOLD DIRTY

Manifold was dirty. Cleaning manifolds will result in better air quality.

Recommendation Contact a qualified HVAC professional.



6.3.1 Distribution System

There are loose connections on ducts, resulting in energy loss. Recommend licensed HVAC contractor resecure.

Recommendation Contact a qualified HVAC professional.



Loose connection; recommend sealing.

7.4.1 Hot Water Systems, Controls, Flues & Vents IRREGULAR FLAME

Water heater flame is irregular. Recommend qualified plumber evaluate & repair.

Recommendation Contact a qualified plumber.



8.4.1 Lighting Fixtures, Switches & Receptacles COVER PLATES DAMAGED

One or more receptacles have a damaged cover plate. Recommend replacement.

Recommendation Contact a qualified electrician.



Scorch marks on cover plate

8.7.1 Carbon Monoxide Detectors

LOW BATTERY

Carbon monoxide detector failed to respond when tested. Recommend battery be replaced.

Recommendation Recommended DIY Project

9.4.1 Exhaust Systems DUCTS LOOSE

Ductwork in the attic is loose or disconnected. Recommend repair.

Recommendation Contact a qualified HVAC professional.



Loose hinges can cause door to stick or eventually fall out of place. Recommend handyman tighten hinges.

Here is a DIY article on fixing loose hinges.

Recommendation Contact a quality handyman.

10.2.1 Windows MISSING SCREEN

Window missing screen. Recommend replacement.

Recommendation Contact a qualified window repair/installation contractor.



Loose tiles are present at time of inspection. Recommend a qualified contractor re-attach and seal.

Recommendation Contact a quality handyman.











Countertop had one or more cracks or chips. Recommend qualified countertop contractor evaluate and repair.

Here is a helpful article on repairing cracks, chips & fissures.

Recommendation Contact a qualified countertop contractor.

